



2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Customer #:	5676508
Payment Terms:	Payment due in 30 days
Invoice #:	36054217
Invoice Date	2026-06-23
Total Due	\$5,812.53

Amount Enclosed: \$

BRIAN STEVENSON
250 DOVERS BRANCH RD
BURNSVILLE, NC 28714

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000567650800005812536

Customer Name		Delivery/Service Address	Cust #	Invoice #	Inv Date
BRIAN STEVENSON		250 DOVERS BRANCH RD - BURNSVILLE, NC 28714	5676508	36054217	2026-06-23
Quantity	Item Number	Description	Unit Price		TOTAL
1.00	Service Labor.	Set 2-120's and run gas line to house and to both htr locations	\$775.0000		\$775.00
1.00	Service Labor.	INSTALLATION OF BOTH HEATERS	\$536.0000		\$536.00
1.00	Permit Fee	Permit Fee	\$135.0000		\$135.00
1.00	EX38DTWP	36,500 BTU Direct Vent Wall Furnace-LP-WHITE	\$2,099.0000		\$2,099.00
1.00	EX22DTWP	8,200-20,700 BTU DIRECT VENT WALL FURNACE WHITE LP	\$1,900.0000		\$1,900.00

Tank/Equipment: Heater - EX38

For Fuel or Service At:

250 DOVERS BRANCH RD - BURNSVILLE, NC 28714

Sub Total	\$5,445.00
Consumables	
Tax Total	\$367.53
TOTAL DUE	\$5,812.53

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

www.blossmangas.com | 828-682-2118

Safety Check



Date: 01-29-2026 Work Order #: 35808680
Acct #: 5676508 Branch: BURNSVILLE
Name: Brian Stevenson
Address: 250 DOVERS BRANCH RD
City: BURNSVILLE State: NC Zip Code: 28714
Phone #: (828) 284-3966 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Spaceheater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 20,700	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Spaceheater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 36,500	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 320AG AM2SH059023	Owned By: Company
Size: LP320AG	Serial #: AM2SH059023	Mfg.: Other
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Kosan	Model: 988tw-17
Flow Pressure: 11	Lock-up Pressure: 12	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Kosan	Model: 988tw-17
Flow Pressure: 10	Lock-up Pressure: 11	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

Piping Pressure Test

Start Pressure: 10 psi	End Pressure: 10 psi	Time Head: 30 MINUTES
------------------------	----------------------	-----------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies. "Venting System" - a system usually composed of vent pipe, a chimney or vent connectors, if used, to form an open passageway for removing flue or vent gases to the outdoors.

I, Brian Stevenson

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature

Cynthia Stevenson

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 35808680

Customer information has changed.

New appliance: Spaceheater

Service Technician: MARK HUDGINS