



REMIT TO:

G&B ENERGY
P.O. BOX 811
ELKIN, NC 28621

G&B ENERGY - WEAVERVILLE
185 NORTH BUNCOMBE SCHOOL RD
WEAVERVILLE, NC 28787
828-645-1007

*** SERVICE INVOICE *** 92069 ***

COSNER HOLDING LLC COSNER HOLDING LLC
401 E INTENDENCIA ST
PENSACOLA, FL 32502

ACCT# 615304 8/07/26

RETURN TOP PORTION WITH YOUR REMITTANCE.
RETURN TOP PORTION WITH YOUR REMITTANCE.

SVC# 1

QUANTITY	DESCRIPTION	AMOUNT
	MEGR-1652D-DFF DTD 9/23/2024	
1.000	NIPPLE 3/4" X 8"	12.08
1.000	NIPPLE 3/4 X 18"	29.22
1.000	BUSHING 1/2 X 3/4	5.42
1.000	PLUMBING ISOLATION KIT 3/4"	135.20
4.000	PVC EL 2" 90	36.90
10.000	PVC PIPE S40 2"	54.94
1.000	PRESSURE TEST	
1.000	PLUMBING SUPPLIES	80.00
1.000	RINNAI RX130IN	1193.23
	RINNAI RX130IN , SERIAL #TH.BA-178729	
	TOTAL PARTS	1961.75
	TOTAL LABOR 6.00 HOURS	600.00
	NC SALES TAX	179.32

<<< TOTAL CHARGE FOR INVOICE # 92069 >>> 2741.07

* CONTINUED * PAGE 2

** Scheduled for 08/06/2026 **

Reason: 2-INSTALLATION

INSTALL WH IN AIR NEW RENTAL UNIT. LEAK CHECK..

Workorder #: 92069

lhensley

Logged on: 08/06/2026 08:40

Printed:

08/06/2026

8:40

Scheduled For: 08/06/2026

Arrive:

Complete:

AR1

Cust#: 615304

S#: 1

DIV: 18

TYP: 1

Zone:WV13

COSNER HOLDING LLC COSNER HOLDING LLC

Tel: (850)525-4777 SRP: 1

LCD:

401 E INTENDENCIA ST

SCT:

SDV: 0.00

AMT: 0.00

SRD:

SCY:

33 LTX

PTX

TWD:

PENSACOLA, FL 32502

CR LIM: COD

BAL: .00

HWG: 0

Delivery: LDD:02/09/2026 40.0000units.(AUTO)DTRO:968SIZE:120LOC:

Service Addr: COSNER HOLDING/407 HIGHLAND CREEK DR/GATE CODE 2276 SEND/MARSHALL NC 28753

Instruct: HWY 251 FLETCHER MARTIN RD, ALEXANDER /RD, BEAR CREEK RD, HIGHLAND CREEK DR, /GATE 2276 SEND, 120AG #F00246252

Site Defn:

Installation Component:

ACCT#:615304

WO #:

92069

S #:

1

Call date: 08/06/2026

Tank Monitor: Set Up or Pick Up Monitor ID _____

Product LP Rate B Use Heat Automatic ☒ Will Call _____

Dwelling Type: Single Family___ Multi Family___ Mobile Home___ Commercial___ Agriculture___

Tank Information			Regulator				
AG or UG	Set Up	Pick up	Brand	Model	Type	Date	Location
Serial No.			Marshall	MEGR 1222H BCF	1st	3.26.25	TANK
Size							
Mfg. Date							
Mfg.							
% LP in Tank							



TYPE : MEGR-1652D-DFF
ORIFICE : 7/32"
SPR. RANGE : 9-13"WC
MAX. INLET : 10 PSI
INTERNAL RELIEF
DIELECTRIC SECOND STAGE
S/N: 040989 23 SEP 21

Pressure Test: Start Time _____ am/pm @ _____ psi/wc Stop Time _____ am/pm @ _____ psi/wc Batch

Leak Check: Start Time 1144 am/pm @ B psi/wc Stop Time 1158 am/pm @ B psi/wc # 12306

Regulator Lock Down: Low Pressure _____ High Pressure _____