



Family Owned & NC Grown
www.gbenergy.com

REMIT TO:

G&B ENERGY
P.O. BOX 811
MILLERS CREEK, NC 28621
G&B ENERGY - MILLERS CREEK
PO BOX 600
MILLERS CREEK, NC 28651
336-973-2411

*** SERVICE INVOICE *** 85991 ***

RICK WHITLEY
1629 ROCK CREEK ROAD
NORTH WILKESBORO, NC 28659 ACCT# 201343 8/14/26

RETURN TOP PORTION WITH YOUR REMITTANCE.
SVC# 1

QUANTITY	DESCRIPTION	AMOUNT
1.000	TOTAL MATERIAL USED	715.00
1.000	PRESSURE TEST	
4.000	FLARE NUT 1/2	
1.000	FLARE TEE 1/2	
1.000	BALL VALVE 3/4 X 3/4	
1.000	MALE FLARE MALE PIPE 1/2 X 3/4	
50.000	TUBING 1/2 KAMCO REFRIG COATED	
2.000	PIPE S40 3/4	
6.000	NIPPLE 3/4	
4.000	ELL 90 3/4	
1.000	TEE 3/4	
2.000	UNION 3/4	
1.000	CAP 3/4" BLACK STEEL	
1.000	RINNAI TANKLESS WATER HEATER 160K BTU	895.00

* CONTINUED * PAGE 1



REMIT TO:

G&B ENERGY
P.O. BOX 811
ELKIN, NC 28621

Family Owned & NC Grown
www.gbenergy.com

G&B ENERGY - MILLERS CREEK
PO BOX 600
MILLERS CREEK, NC 28651
336-973-2411

*** SERVICE INVOICE *** 85991 ***

RICK WHITLEY
1629 ROCK CREEK ROAD
NORTH WILKESBORO, NC 28659 ACCT# 201343 8/14/26

RETURN TOP PORTION WITH YOUR REMITTANCE.
SVC# 1

QUANTITY	DESCRIPTION	AMOUNT
	TF.UA-081296	
1.000	VENT KIT FOR R75LSI/R94LSI	
1.000	PEX STYLE ISOLATION VALVE KIT 3/4	
20.000	PEX SLEEVING 3/4	
1.000	MEGAPRS ADAPT PXMT 3/4 QVG-25106	
1.000	REG 2ND STAGE DIELECTRIC MEGR1622DDFF	
	TOTAL PARTS	1610.00
	TOTAL LABOR 1.00 HOURS	800.00
	NC SALES TAX	168.70
	WHITE GOODS TAX	3.00

<<< TOTAL CHARGE FOR INVOICE # 85991 >>> 2581.70

SITE: RICK WHITLEY/1629 ROCK CREEK ROAD//NORTH WILKESBORO NC 286590000
DISPATCH DATE: 8/14/26

* CONTINUED * PAGE 2

Date 8-14-26 Technician BG, LR Time In 9:30 Time Out 2:10

Customer Name Rich Whitlay Tubing 3/8 _____ 1/2 _____ 5/8 _____

Account Number 20343 KC Tubing 3/8 _____ 1/2 50'

	NS-4	3/8	<u>4</u>		49	3/8x1/4	
	NS-4	1/2			49	3/8x3/8	
	NS-4	5/8			49	3/8x1/2	
	NRS-4	1/2x3/8			49	3/8x3/4	
	26	3/8			49	1/2x1/4	
	26	1/2			49	1/2x3/8	
	26	5/8			49	1/2x1/2	
	27	3/8			49	1/2x3/4	
	27	1/2			49	5/8x3/8	
	27	5/8			49	5/8x1/2	
	27	5/8			49	5/8x3/4	
	42	3/8			48	1/4x1/4	
	42	1/2			48	3/8x1/4	
	42	5/8			48	3/8x3/8	
	42R	3/8x1/4			48	3/8x1/2	
	42R	1/2x3/8			48	3/8x3/4	
	42R	5/8x3/8			48	1/2x1/4	
	42R	5/8x1/2			48	1/2x3/8	
	55	3/8			48	1/2x1/2	
	55	1/2			48	1/2x3/4	
	55	5/8			48	5/8x3/8	
	55R	1/2x3/8			48	5/8x1/2	
	55R	5/8x3/8			48	5/8x3/4	
	55R	5/8x1/2			54	3/8x3/8	
	44	3/8			54	3/8x1/2	
	44	1/2			54	3/8x3/8	
	44	5/8			54	1/2x3/8	
	44R	3/8x3/8x1/2			54	1/2x1/2	
	44R	1/2x3/8x3/8			54	1/2x3/4	
	44R	1/2x1/2x3/8			54	5/8x1/2	
	44R	5/8x5/8x3/8			54	5/8x3/4	
	44R	5/8x5/8x1/2			46	3/8x1/4	
	T200	3/8			46	3/8x3/8	
	T200	1/2			46	3/8x1/2	
	T200	5/8			46	3/8x3/4	
					46	1/2x3/8	
					46	1/2x1/2	
					46	1/2x3/4	
					46	5/8x3/8	
					46	5/8x1/2	
					46	5/8x3/4	

1/2" Pipe _____ PI1/2S4OT
Nipple _____ NIP1/2
Ell _____ EL1/290
Street L _____ EL1/290ST
Tee _____ TEE1/2
Union _____ UN1/2
Cap _____ CAP1/2
Reducer _____ x _____

3/8" Pipe _____ PI3/8S4OT
Nipple _____ NIP3/8
Ell _____ EL3/890
Street L _____ EL3/890ST
Tee _____ TEE3/8
Union _____ UN3/8
Cap _____ CAP3/8
Reducer _____ x _____

3/4" Pipe _____ PI3/4S4OT
Nipple _____ NIP3/4
Ell _____ EL3/490
Street L _____ EL3/490ST
Tee _____ TEE3/4
Union _____ UN3/4
Cap _____ CAP3/4
Reducer _____ x _____

1" Pipe _____ PI1S4OT
Nipple _____ NIP1
Ell _____ EL190
Street L _____ EL190ST
Tee _____ TEE1
Union _____ UN1
Cap _____ CAP1
Reducer _____ x _____

Appliance Model _____ Serial _____
Appliance Model _____ Serial _____
Appliance Model _____ Serial _____



Model: RE1601P
(REU-VE2125FFD-US)
Serial: TF UA-081296

21" vent kit = 1
my PEX valve kit = 1
my PEX = 20'
my vent kit X PEX = 20'



Contract Labor _____

CO Detector? yes _____ no _____
If customer supplied: Signature _____

Miscellaneous Parts and Comments
Removal old tanked w/lt. Installed RE160.
Fired into gas line by tech. installed second stage.
10 min leak test passed. Fired off furnace, lost
pilot on on VF heater.