

Safety Check



Date: 11-14-2025 Work Order #: 5548065

Acct #: 5548065 Branch: MARSHVILLE

Name: Jarrold Edwards

Address: 207 Gaddy Road

City: Marshville State: NC Zip Code: 28103

Phone #: (704) 221-8105 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a Existing Installation

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: AO smith
Age: 10Plus	Input BTU: 199,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: Gas	Manufacturer: Whirlpool
Age: 10Plus	Input BTU: 20,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Dryer	Type: Gas	Manufacturer: Speed queen
Age: New	Input BTU: 22,500	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas pack	Type: Gas	Manufacturer: Goodman
Age: 2	Input BTU: 800,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Generator	Type: Gas	Manufacturer: Genarac
Age: 5	Input BTU: 325	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: Customer Owned 250 No	Owned By: Company
Size: No Item Number250	Data Plate (Van Der Veer) Serial #: 1294	Mfg.: Worthington Cylinders
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: Tr9
Flow Pressure: 9.8	Lock-up Pressure: 10.2	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Rego	Model: B4
Flow Pressure: 10.8	Lock-up Pressure: 11.1	

System Leak Check

Start Pressure: 100 psi	End Pressure: 100 psi	Time Head: 10 MINUTES
-------------------------	-----------------------	-----------------------

Piping Pressure Test

Start Pressure: NA psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------


CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Jarrod Edwards

Know how to turn off gas in case of emergency,
 Have smelled propane/natural gas and can detect its odor,
 Have received the consumer safety information,
 I am satisfied with the service work performed.

Customer Signature

A handwritten signature in black ink, enclosed in a rectangular box. The signature is stylized and appears to read "J. Morgan".

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 5548065

New appliance: Dryer installed new dryer and perform safety check

Service Technician: DANNY MORGAN
