

Safety Check



Date: 11-24-2025 Work Order #: 5622295

Acct #: 5622295 Branch: MARSHVILLE

Name: Jon And Katelyn Wright

Address: 2042 Old Peachland Rd

City: Marshville State: NC Zip Code: 28103

Phone #: (704) 681-1410 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: AO smith
Age: New	Input BTU: 50,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: Gas	Manufacturer: Wolf
Age: New	Input BTU: 100,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Dryer	Type: Gas	Manufacturer: Speed queen
Age: New	Input BTU: 30,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Gas Logs	Type: Gas	Manufacturer: Empire
Age: New	Input BTU: 30,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Heat unit	Type: Gas	Manufacturer: American standard
Age: New	Input BTU: 60,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Heat unit	Type: Gas	Manufacturer: American standard
Age: New	Input BTU: 60,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Generator	Type: Gas	Manufacturer: Cumming
Age: New	Input BTU: 350,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 325@ residence	Owned By: Company
Size: LP325AG	Serial #: 2SH100760_Marshville	Mfg.: American Welding & Tank
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: Tr96
Flow Pressure: 09.7	Lock-up Pressure: 10.1	

2 PSI	Manu.: Rego	Model: Y4
Flow Pressure: 1.8	Lock-up Pressure: 2.1	

2nd/Final Stage	Manu.: Maxitrol	Model: 325
Flow Pressure: 10.8	Lock-up Pressure: 11.2	

System Leak Check

Start Pressure: 140 psi	End Pressure: 140 psi	Time Head: 10 MINUTES
-------------------------	-----------------------	-----------------------

Piping Pressure Test

Start Pressure: NA psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Jon And Katelyn Wright

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature

A large rectangular box containing a handwritten signature in black ink. The signature reads "Jon Wright" in a cursive, flowing script.

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 5622295

New appliance: Water Heater

New appliance: Range/Cooktop

New appliance: Dryer

New appliance: Gas Logs

New appliance: Heat unit

New appliance: Generator

Service Technician: DANNY MORGAN