



2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Customer #:	2592927
Payment Terms:	Payment due in 30 days
Invoice #:	33195897
Invoice Date	2025-11-14
Total Due	\$2,204.50

Amount Enclosed: \$ _____

TODD SNELSON
2629 WALNUT CREEK RD
MARSHALL, NC 28753

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000259292700002204505

Customer Name		Delivery/Service Address	Cust #	Invoice #	Inv Date
TODD SNELSON		2629 WALNUT CREEK RD - MARSHALL, NC 28753	2592927	33195897	2025-11-14
Quantity	Item Number	Description	Unit Price	TOTAL	
1.00	064063	Gas line needed (first 35')	\$621.3900	\$621.39	
1.00	Discount - Labor	Labor Discount	-\$73.1100	-\$73.11	
1.00	Permit Fee	Permit Fee	\$135.0000	\$135.00	
1.00	SP	MISC SERVICE PARTS QUICK DISCONNECTS FOR GRILL X2	\$278.0000	\$278.00	
1.00	RX180IN	180K BTU NG OR LP INDOOR/OUTDOOR TANKLESS WATER HEATER	\$1,099.0000	\$1,099.00	
1.00	LABOR	LABOR	\$0.0000	\$0.00	
0.02	LABOR	LABOR	\$0.0000	\$0.00	

Tank/Equipment: Water Heater - WATER HEATER

For Fuel or Service At:

2629 WALNUT CREEK RD - MARSHALL, NC 28753

Sub Total	\$2,060.28
Consumables	
Tax Total	\$144.22
TOTAL DUE	\$2,204.50

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

www.blossmangas.com | 828-682-2118

Safety Check



Date: 12-01-2025 Work Order #: 33542637

Acct #: 2592927 Branch: BURNSVILLE

Name: Todd Snelson

Address: 2629 WALNUT CREEK RD

City: MARSHALL State: NC Zip Code: 28753

Phone #: (828) 776-7352 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 180,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Container(s)

Type: Tank	Desc: 1000UG SER#	Owned By: Company
Size: LP1000UG	AM2SY027916 HOUSE Serial #: AM2SY027916	Mfg.: American Welding & Tank
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: 4403
Flow Pressure: 10	Lock-up Pressure: 10	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Rego	Model: 4403
Flow Pressure: 11.5	Lock-up Pressure: 12.5	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

Piping Pressure Test

Start Pressure: NA psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Todd Snelson

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:
Safety Check
Fuel Type: Propane
Work Order #: 33542637
New appliance: Water Heater

Service Technician: KEVIN ROBINSON
