



Leak Check Report

Customer No.: 7472530 Customer Name: STUART POCOCK
Date of Inspection: 02-06-2025 10:50 PM Ticket Number:
CSC Location: 1809 Cashiers, NC

Customer Information

Service Address: 289 RED MAPLE RD Cullowhee NC 28723
Billing Address: 289 RED MAPLE RD CULLOWHEE NC 28723
Tank ID:: 1726664
Tank Description: 1-289 RED MAPLE RD CULLOWHEE NC 2872-500-1335623

Test Results

Type of Test: 0-300 Test Block Tank Pressure: 110 psi
Start Pressure: 88 psi End Pressure: 88 psi
Start Time: 02-06-2025 10:50 AM End Time: 02-06-2025 11:00 AM
Test Status: Pass Tagged & locked:

Reason:

Leak Check includes all stages

Service Technician Acknowledgement

Technician Name: Whitehead, William R

Date: 02-06-2025 02:14 PM

A handwritten signature in black ink, appearing to be "B IIII".

Signature

SERIAL #: SL. UA-162964



ASSEMBLED IN GRIFFIN 23-3165
Model #: RE199i (REU-VE2737FFD-US)

CSA/ANSI Z21.10.3 • CSA 4.3-2019



This water heater requires a special venting system.
Refer to the installation instructions for parts list
and method of installation. This equipment complies with
the requirements of ASHRAE Standard 90.1.

Type of Gas:

Input Rating

Maximum:

Minimum:

Maximum Inlet Gas Pressure:

Propane Gas

199,000 BTU/H

10,400 BTU/H