

Safety Check



Date: 03-27-2025 Work Order #: 31250014
Acct #: 5491901 Branch: STATESVILLE
Name: Loyd Marlowe
Address: 601 NORTH MEADOW RD
City: HARMONY State: NC Zip Code: 28634
Phone #: (980) 635-3080 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a Existing Installation

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Bradford White
Age: New	Input BTU: 36,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: Electric	Manufacturer: LG
Age: 3	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: Electric	Manufacturer: LG
Age: 6	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Furnace	Type: Gas	Manufacturer: Trane
Age: 8	Input BTU: 199,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 500 UG SN#M2248837	Owned By: Company
Size: LP500UG	Serial #: M2248837	Mfg.: Manchester
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Kosan	Model: 988hp08
Flow Pressure: 10	Lock-up Pressure: 11	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Rego	Model: 4403lv
Flow Pressure: 10	Lock-up Pressure: 11	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Loyd Marlowe

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature

Loyd Marlowe

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 31250014

Customer information has changed.

New appliance: Water Heater

Service Technician: LOYD MARLOWE
