

Safety Check



Date: 03-10-2025 Work Order #: 31035406
Acct #: 2781926 Branch: STATESVILLE
Name: Billy S. Mccoy
Address: 189 BOSTAIN LAKE RD
City: STATESVILLE State: NC Zip Code: 286779051
Phone #: (704) 873-3377 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a Existing Installation

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Bradfordwhite
Age: New	Input BTU: 36,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: Electric	Manufacturer: Frigidaire
Age: 7	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: Electric	Manufacturer: Whirlpool
Age: 10	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: Gas	Manufacturer: Monessen
Age: 10Plus	Input BTU: 35,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 500AG SN#TR114342	Owned By: Company
Size: LP500AG	Serial #: TR114342	Mfg.: Trinity
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: 4403lv
Flow Pressure: 10	Lock-up Pressure: 11	
2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	
2nd/Final Stage	Manu.: Rego	Model: 4403
Flow Pressure: 11	Lock-up Pressure: 12	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Billy S. Mccoy

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature

Wanda M^{rs} McCoy

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 31035406

New appliance: Water Heater

Service Technician: LOYD MARLOWE
