

Safety Check



Customer Account Number
5599425

Date
2025-02-04

Work Order #
30574463

Branch
STATESVILLE

Name
KRISTEN SARAGONI

Customer Email
BDEVELOPMENT816@GMAIL.COM

Address
125 LAKELAND RD

City
MOORESVILLE

State
NC

Zip
28117

Phone #
(704) 235-7138

Alt. Phone #

Has contact information been updated?
YES

☒ Walk-Through Visual Inspection

☒ Leak Check

☒ Safety Check

☐ Existing Installation

☒ New Installation

Appliances

Appliance Water Heater	Type GAS	Manufacturer Rannia	Age of Appliance (In Years) New
Input of BTU 199,000	Appliance Converted LP	Control Safety System OK	Combustion Chamber OK
Combustion Air OK	Venting System OK	Red Tagged NO	

Appliance Range/Cooktop	Type GAS	Manufacturer LG	Age of Appliance (In Years) New
Input of BTU 42,000	Appliance Converted LP	Control Safety System OK	Combustion Chamber OK
Combustion Air OK	Venting System OK	Red Tagged NO	

Appliance Dryer	Type ELECTRIC	Manufacturer LG	Age of Appliance (In Years) New
Input of BTU	Appliance Converted Please Choose	Control Safety System Please Choose	Combustion Chamber Please Choose

Combustion Air Please Choose	Venting System Please Choose	Red Tagged Please Choose
---------------------------------	---------------------------------	-----------------------------

Appliance Gas Logs	Type GAS	Manufacturer Empire	Age of Appliance (In Years) New
Input of BTU 56,000	Appliance Converted LP	Control Safety System OK	Combustion Chamber OK
Combustion Air OK	Venting System OK	Red Tagged NO	

Equipment

Equipment Type Tank	Equipment Description 2 120 AG TANKS	Owned By Company
Size LP120AG	Serial Number WO2597264	Manufacturer Worthington Cylinders
Condition OK	Relief Valve Cap OK	Fittings Leak Test OK

Regulator Operation

1st Stage	Manufacturer Kosan	Model 988tw-17	Flow Pressure 10 psi	Lock-Up Pressure 11 psi
2 PSI	Manufacturer NA	Model	Flow Pressure psi	Lock-Up Pressure psi
2nd/Final Stage	Manufacturer Kosan	Model 988tw-17	Flow Pressure 10 w.c.	Lock-Up Pressure 11 w.c.

System Leak Check

Leak Check Pass/Failed
PASSED

☒ Low Pressure ☐ High Pressure

Start Pressure
9

End Pressure
9

Time Held
3

Minutes/Hours
MINUTES

W.C.

W.C.

Piping Pressure Test

Start Pressure 30	End Pressure 30	Time Held 15	Minutes/Hours MINUTES
----------------------	--------------------	-----------------	--------------------------

CO Reading
0

PPM (Based on the U.S. Consumer Product Safety Commission, readings should be below 30ppm)

DISCLAMIER: This Safety Check/Leak Check covers LP/Nat gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, KRISTEN SARAGONI

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information

Here received the consumer safety information,
I am satisfied with the service work performed.

A handwritten signature in black ink, consisting of a series of loops and a long horizontal stroke.

Sign in the box above

Date

2025-02-04

Comments

Customer information has changed. New appliance: Water Heater New appliance: Range/Cooktop New ap

Representative Name

503 LOYD MARLOWE