

Safety Check



Date: 06-27-2025 Work Order #: 32080174
Acct #: 322003 Branch: BOONE
Name: David Robertson
Address: 273 MIDVALLEY RD
City: BLOWING ROCK State: NC Zip Code: 286059594
Phone #: (828) 773-8666 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 199,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Container(s)

Type: Tank	Desc: 1000 UG S#QU688579 --	Owned By: Company
Size: LP1000UG	SORRENTO HLDS Serial #: QU688579	Mfg.: Quality Steel
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Kosan	Model: 988HP-05
Flow Pressure: 9	Lock-up Pressure: 10	

2 PSI	Manu.: Fisher	Model: R522E-BCH
Flow Pressure: 2	Lock-up Pressure: 2.1	

2nd/Final Stage	Manu.: Maxitrol	Model: 325-5L
Flow Pressure: 11.5	Lock-up Pressure: 12.5	

System Leak Check

Start Pressure: 9.5 w.c	End Pressure: 9.5 w.c	Time Head: 3 MINUTES
-------------------------	-----------------------	----------------------


CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, David Robertson

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:

Safety Check

Fuel Type: Propane

Work Order #: 32080174

New appliance: Water Heater

Service Technician: PATRICK SMITH
