Safety Check



Date: 06-26-2025	Work Order #: _32039	9867	
Acct #: 5585257	Branch: BURNSVIL	LE	
Name: Jonathan And Kim Beni	nett		
Address: 1181 HORTON HILL			
City: GREEN MTN		State: NC Zip Code: 28740	
Phone #: <u>(828)</u> 208-4631	Ait	Phone #:	
Services Performed: Walk-throu	igh Visual Inspection, Leak Check,	Safety Check on a New Install	
Appliances			
Appliance: Water Heater	Type: Gas	Manufacturer: Rinnai	
Age: New	Input BTU: 180,000	Appliance Converted: LP	
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK	
Venting System: OK	Red Tagged: No	5N. RE180ip - Tc a	
Appliance: Range/Cooktop	Type: None	Manufacturer:	
Age:	Input BTU:	Appliance Converted:	
Control Safety System:	Combustion Chamber:	Combustion Air:	
Venting System:	Red Tagged:		
Appliance: Dryer	Type: None	Manufacturer:	
Age:	Input BTU:	Appliance Converted:	
Control Safety System:	Combustion Chamber:	Combustion Air:	
Venting System:	Red Tagged:		
Appliance: Gas Logs	Type: Gas	Manufacturer: Buck	
Age: 5	Input BTU: 33,000	Appliance Converted: LP	
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK	
Venting System: OK	Red Tagged: No		
Container(s)			
Type: Tank	Desc: 320UG	Owned By: Company	
Size: LP320UG	Serial #: M2433425	Mfg.: Manchester	
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK	

Type: Tank	Desc: 320UG	Owned By: Company
Size: RE180IP	Serial #: tc ua-036253	Mfg.: Manchester
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Kosan	Model: 988hp-05
Flow Pressure: 10	Lock-up Pressure: 10	

2 PSI	Manu.: Kosan	Model: 998tp-08	
Flow Pressure: 2	Lock-up Pressure: 2		

2nd/Final Stage	Manu.: Maxitrol	Model: 325-5I	
Flow Pressure: 11	Lock-up Pressure: 13		

System Leak Check

		Time Used 2 MINIUTES
Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Jonathan And Kim Bennett

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments: Safety Check

Fuel Type: Propane Work Order #: 32039867

Customer information has changed. New appliance: Water Heater

Service Technician: DANIEL BRANTON



JONATHAN AND KIM BENNETT 1181 HORTON HILL GREEN MTN, NC 28740

Invoice #: 31963349
Invoice Date 2025-06-19
Total Due \$2,479.11

Amount Enclosed: \$

BLOSSMAN GAS & APPLIANCE 2138 WEST US HIGHWAY 19E BURNSVILLE, NC 28714

000558525700002479119

Cus	tomer Name	Delivery/Service Address	Cust #	Invoice #	Inv Date
JONATHAN	AND KIM BENNETT	1181 HORTON HILL - GREEN MTN, NC 28740	5585257	31963349	2025-06-19
Quantity	Item Number	Description	Unit Pri	ce	TOTAL
1.00	064298	Install Interior Tankless Water Heater *Standard Installation	\$97	9.1400	\$979.14
1.00	064127	Interior Tankless Water Heater - Wall/Roof vent kit	\$25	8.3600	\$258.36
1.00	070130	APPLIANCE REGULATOR	\$12	4.8600	\$124.86
1.00	RE180IP	Rinnai RE Series 8.5 GPM Indoor NCTWH - LP	\$95	0.0000	\$950.00

Tank/Equipment:

Fuel Tank - 320UG

For Fuel or Service At:

1181 HORTON HILL - GREEN MTN, NC 28740

\$2,312.36	Sub Total
\$9.99	Consumables
\$156.76	Tax Total
\$2,479.11	TOTAL DUE