



2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Customer #:	5508666
Payment Terms:	Payment due in 30 days
Invoice #:	31673128
Invoice Date	2025-06-16
Total Due	\$2,317.06

Amount Enclosed: \$ _____

JAMES R./ TAMMY FOX
280 FOX HILL RD
BURNSVILLE, NC 28714

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000550866600002317067

Customer Name		Delivery/Service Address	Cust #	Invoice #	Inv Date
JAMES R./ TAMMY FOX		280 FOX HILL RD - BURNSVILLE, NC 28714	5508666	31673128	2025-06-16
Quantity	Item Number	Description	Unit Price		TOTAL
1.00	064063	Gas line needed (first 35')	\$548.2800		\$548.28
1.00	064063	Gas line needed (first 35')	\$548.2800		\$548.28
1.00	FC824P	Rinnai 24K BTU LP Vent-Free Fan Convactor	\$964.0000		\$964.00
1.00	Permit Fee	Permit Fee	\$100.0000		\$100.00

SN - R.A. LB- 000604

Tank/Equipment: Fuel Tank - 2-120AG AM2SL030821 & TRM1331821 UPPER HOUSE

For Fuel or Service At:

280 FOX HILL RD - BURNSVILLE, NC 28714

Sub Total	\$2,160.56
Consumables	\$9.99
Tax Total	\$146.51
TOTAL DUE	\$2,317.06

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

www.blossmangas.com | 828-682-2118

Safety Check



Date: 06-25-2025 Work Order #: 31673187
Acct #: 5508666 Branch: BURNSVILLE
Name: JAMES R./ TAMMY FOX
Address: 280 FOX HILL RD
City: BURNSVILLE State: NC Zip Code: 28714
Phone #: (828) 284-9678 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: Gas	Manufacturer: Peterson
Age: New	Input BTU: 32,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: N/A	Red Tagged: No	

Appliance: Space heater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 20,700	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: N/A	Red Tagged: No	

Appliance: Generator	Type: Gas	Manufacturer: Cummins
Age: New	Input BTU: 265,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 2-120AG AM2SL030821 & TRM1331821 UPPER HOUSE	Owned By: Company
Size: LP120AG	Serial #: TRM1331821	Mfg.: Trinity
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: V404b39
Flow Pressure: 10	Lock-up Pressure: 10	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Rego	Model: V404b39
Flow Pressure: 11	Lock-up Pressure: 12	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

CO READINGS 2 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, JAMES R./ TAMMY FOX

Know how to turn off gas in case of emergency,
 Have smelled propane/natural gas and can detect its odor,
 Have received the consumer safety information,
 I am satisfied with the service work performed.

Customer Signature

Part I

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 31673187

New appliance: Gas Logs

Service Technician: DANIEL BRANTON