



2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

INVOICE

Page 1 of 1

Customer #:	5387907
Payment Terms:	Payment due in 30 days
Invoice #:	31952859
Invoice Date	2025-07-03
Total Due	\$1,807.23

Amount Enclosed: \$

ZOE ROTHFUSS
82 SUNCREST DR
MARS HILL, NC 28754

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000538790700001807237

Customer Name		Delivery/Service Address	Cust #	Invoice #	Inv Date
ZOE ROTHFUSS		82 SUNCREST DR - MARS HILL, NC 28754	5387907	31952859	2025-07-03
Quantity	Item Number	Description	Unit Price		TOTAL
1.00	064380	Final Hookup and Inspection (Level 2) LABOR ONLY	\$230.0000		\$230.00
1.00	RX160IN	160K BTU NG OR LP INDOOR/OUTDOOR TANKLESS WATER HEATER	\$1,459.0000		\$1,459.00

SN - SL.BA-189212

Tank/Equipment: Water Heater -

For Fuel or Service At:

82 SUNCREST DR - MARS HILL, NC 28754

Sub Total	\$1,689.00
Consumables	
Tax Total	\$118.23
TOTAL DUE	\$1,807.23

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

www.blossmangas.com | 828-682-2118

Safety Check



Date: 07-03-2025 Work Order #: 31952859
Acct #: 5387907 Branch: BURNSVILLE
Name: Zoe Rothfuss
Address: 82 SUNCREST DR
City: MARS HILL State: NC Zip Code: 28754
Phone #: (919) 717-6588 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 160,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Furnace	Type: Gas	Manufacturer: American standard
Age: 2	Input BTU: 78,500	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 320UG TR117561	Owned By: Company
Size: LP320UG	Serial #: TR117561	Mfg.: Trinity
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Kosan	Model: 984hp-04
Flow Pressure: 10.25	Lock-up Pressure: 10.25	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Kosan	Model: 998plp
Flow Pressure: 11	Lock-up Pressure: 11.5	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 4 MINUTES
-----------------------	---------------------	----------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Zoe Rothfuss

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:

Safety Check

Fuel Type: Propane

Work Order #: 31952859

New appliance: Water Heater

Service Technician: DANIEL BRANTON
