

Safety Check



Date: 08-05-2025 Work Order #: 32465932
Acct #: 5231275 Branch: HENDERSONVILLE
Name: Antoine & Lury Ignizio
Address: 40 LOFTY PINE LANE
City: MILLS RIVER State: NC Zip Code: 28759
Phone #: (828) 489-6715 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Navien
Age: New	Input BTU: 199,900	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Container(s)

Type: Tank	Desc: Tank #1 ANTOINE & LURY	Owned By: Company
Size: LP320AG	IGNIZIO Serial #: DECC3294	Mfg.: Other
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Cavagna	Model: 988hp05
Flow Pressure: 9.9	Lock-up Pressure: 12	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Cavagna	Model: 998lp03
Flow Pressure: 11.7	Lock-up Pressure: 13	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

Piping Pressure Test

Start Pressure: Na psi	End Pressure: psi	Time Head:
------------------------	-------------------	------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Antoine & Lury Ignizio

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:

Safety Check

Fuel Type: Propane

Work Order #: 32465932

New appliance: Water Heater

Service Technician: JOSHUA CARNES
