



PROPANE SAFETY INSPECTION



Account # Dunn- 100# Name Susan Dunn Address 112 Dale Adams Rd City Sugar Grove

State NC Zip 28679 Phone 828-719-6109 Date of Inspection 12/03/2024 Branch/Location _____ Work Order # _____

Equipment Type	Furnace	Cooktop		
Manufacturer	Rheem	KENMORE		
Year Manufactured				
Model #	R951T0603A17M4SNAS	911. 32259591		
Serial #	W322422211	8F718549Q		
Fuel	Propane	Propane		
BTUs (Maximum Input)	56,000	11,000		
Manual Shutoff Valve	OK	OK		
Sediment Trap	OK	N/A		
Burner(s) Condition	Service Not Provided	OK		
Combustion Chamber Condition	Service Not Provided	Service Not Provided		
Control/Pilot Safety System	Service Not Provided	Service Not Provided		
Venting System	Service Not Provided	N/A or No		
Combustion Air	Service Not Provided	OK		
Taken Out of Svc or Operation (Tag #)	No	No		

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve		Fittings Leak Test	
			ASME/ DOT	AG/UG/AGUG					Last Requal Date	Type	Found.	Loc.	Cond.	Cond.	Date		Cap
	6SH 053108	N	ASME	AG	325 wg		American welding and	2011	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING		Material	Size	Protection	REGULATOR(S)		Mfr.	Model #	Date Code	Cond.	Vent Position	Protection
2nd Stg	CT (Copper Tubing)	3/8	OK	2nd Stg	Maxitrol	325-3L	2023	OK	OK	OK		
2nd Stg	CT (Copper Tubing)	1/2	OK									

CSST TRACKING (IF APPLICABLE) Bonded Yes No Unknown Jurisdictional Acct. Y N Unknown Gas Lines Capped Y N/A

System Type	System Leak Check <input checked="" type="checkbox"/> Entire System				Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time	Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
1st Stage	55 / 40	<input type="checkbox"/> WC <input checked="" type="checkbox"/> PSI	<input type="checkbox"/> WC <input checked="" type="checkbox"/> PSI	2:30	2:40	PSI	PSI			<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI	
2nd Stage		<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI			PSI	PSI			<input checked="" type="checkbox"/> WC <input type="checkbox"/> PSI	12.5 <input type="checkbox"/> WC <input type="checkbox"/> PSI	
		<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI			PSI	PSI			<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI	
		<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI			PSI	PSI			<input type="checkbox"/> WC <input type="checkbox"/> PSI	<input type="checkbox"/> WC <input type="checkbox"/> PSI	

Performed Sniff Test Y N Comments Furnace was not ready to be fired yet set a good lock up for them when ready to fire appliance.;

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, Property Owner Tenant Authorized Representative, **acknowledge** that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. **I further acknowledge** that:


- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.


In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- Propane Safety Booklet (PRC-005606)
- Important Propane Safety Information for You and Your Family Brochure (PRC-003121)
- Carbon Monoxide Brochure (PRC-000075)

Zach Dollar
Service Technician Name - Print

Service Technician Signature
12/03/2024
Date

Susan Dunn
Customer Name - Print

Customer Signature
12/03/2024
Date