



INVOICE Page 1 of 1

Customer #:	5595194		
Payment Terms:	COD		
Invoice #:	29370273		
Invoice Date	2024-11-01		
Total Due	\$1,321.42		

Amount Enclosed: \$ _____

JOHNNY DEYTON
42 DEYTON HEIGHTS
BURNSVILLE, NC 28714

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000559519400001321422

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
JOHNNY DEYTON		42 DEYTON HEIGHTS - BURNSVILLE, NC 28714		5595194	29370273	2024-11-01
Quantity	Item Number	Description	Unit Price	TOTAL		
1.00	064057	Install Tanks *Standard Installation	\$417.7200	\$417.72		
1.00	Discount - Labor	Labor Discount	-\$208.8600	-\$208.86		
1.00	SP	MISC SERVICE PARTS COPPER	\$60.0000	\$60.00		
1.00	RE160IP	RINNAI RE SERIES 6.6 GPM INDOOR NCTWH LP	\$969.0000	\$969.00		

Tank/Equipment: Fuel Tank - 42 DEYTON HEIGHTS 120AG

For Fuel or Service At:
42 DEYTON HEIGHTS - BURNSVILLE, NC 28714

Sub Total	\$1,237.86
Consumables	
Tax Total	\$83.56
TOTAL DUE	\$1,321.42

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Safety Check

meeting - 380 Rice Rd
Burnsville NC
28714



Rebate

Customer Account Number
5595194

Date
2024-12-12

Work Order #
29843976

Branch
BURNSVILLE

Name
JOHNNY DEYTON

Customer Email

Address
42 DEYTON HEIGHTS

City
BURNSVILLE

State
NC

Zip
28714

Phone #
(828) 208-4125

Alt. Phone #

Has contact information been updated?
Please Choose

Walk-Through Visual Inspection
 Leak Check
 Safety Check
 Existing Installation
 New Installation

Appliances

Appliance	Type	Manufacturer	Age of Appliance (In Years)
Water Heater	GAS	Rinnai	New
Input of BTU 160,000	Appliance Converted LP	Control Safety System OK	Combustion Chamber OK
Combustion Air OK	Venting System OK	Red Tagged NO	

Appliance	Type	Manufacturer	Age of Appliance (In Years)
Range/Cooktop	NONE		Please Choose
Input of BTU	Appliance Converted Please Choose	Control Safety System Please Choose	Combustion Chamber Please Choose
Combustion Air Please Choose	Venting System Please Choose	Red Tagged Please Choose	

Appliance	Type	Manufacturer	Age of Appliance (In Years)
Dryer	NONE		Please Choose
Input of BTU	Appliance Converted Please Choose	Control Safety System Please Choose	Combustion Chamber Please Choose

Combustion Air
Please Choose

Venting System
Please Choose

Red Tagged
Please Choose

Appliance Gas Logs	Type NONE	Manufacturer	Age of Appliance (In Years) Please Choose
Input of BTU	Appliance Converted Please Choose	Control Safety System Please Choose	Combustion Chamber Please Choose
Combustion Air Please Choose	Venting System Please Choose	Red Tagged Please Choose	

Equipment

Equipment Type Tank	Equipment Description 120AG WO2339875 BACK TANK	Owned By Company
Size LP120AG	Serial Number WO2339875	Manufacturer Worthington Cylinders
Condition OK	Relief Valve Cap OK	Fittings Leak Test OK

Regulator Operation

1st Stage	Manufacturer	Model	Flow Pressure	Lock-Up Pressure
	Kosan	988TW-17	10 psi	10.25 psi

2 PSI	Manufacturer	Model	Flow Pressure	Lock-Up Pressure
	NA		psi	psi

2nd/Final Stage	Manufacturer	Model	Flow Pressure	Lock-Up Pressure
	Kosan	988TW-17	10.5 w.c.	12 w.c.

System Leak Check

Leak Check Pass/Failed
PASSED

Low Pressure High Pressure

Start Pressure	End Pressure	Time Held	Minutes/Hours
9 w.c.	9 w.c.	6	MINUTES

Piping Pressure Test

Start Pressure	End Pressure	Time Held	Minutes/Hours
NA	psi		Please Choose

CO Reading
1

PPM (Based on the U.S. Consumer Product Safety Commission, readings should be below 30ppm)

DISCLAIMER: This Safety Check/Leak Check covers LP/Nat gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, JOHNNY DEYTON

- Know how to turn off gas in case of emergency,
- Have smelled propane/natural gas and can detect its odor,
- Have received the consumer safety information,
- I am satisfied with the service work performed.