

MCLAMB'S LP GAS & SUPPLY

3469 NC 242 SOUTH BENSON, NC 27504
(919) 894-3842 info@mclambslpgas.com

PROPANE SAFETY SHEET

Service Date 1/13/2025

County Johnston

Account Number 11111111

Directions _____

Name Limmy Lee

Address 6552-C Bodwin Lake Rd

Dunn NC 28834

Phone 919-868-4649

Closest Customer _____

APPLIANCE			WORK DESCRIPTION
TYPE	Water Heater		
MANUFACTURER	Rinnai		
MODEL #	RE199E		
SERIAL #	RDCWA054537		
LOCATION	but side		
BTU	199000		
AGE	New		
MANUAL SHUTOFF	✓		
VENTING	✓		
SEDIMENT TRAP	✓		
RED TAG	_____		

TANK OWNED BY: Company X Customer _____

The customer acknowledges that he/she (1) knows how to turn off gas in emergencies, (2) has smelled and can detect propane odor, (3) has received other safety instructions, (4) understands any gas problems and corrections, (5) is satisfied with the work performed, and (6) that the customer acknowledges tank ownership as indicated above. The serviceman acknowledges that he/she (1) performed odor test, (2) performed a leak test and pressure test, and (3) has given the customer safety instructions.

Customer Signature _____

Serviceman Signature [Signature]

TANK SPECIFICS

SIZE	SERIAL #	MFG	MFG DATE	LOCATION	CONDITION	LEAK TEST
250	333513			outside	✓	✓

PIPING/REGULATOR

REGULATOR TYPE	PIPING MATERIAL	PIPING SIZE	REGT DATE	MFG/MODEL	REG VENT PROTECT
Int Two-Stage					
1 st Stage	Copper	1/2	24	Fisher	Down
2 nd Stage	Steel	3/4	24	Down Fisher	Down

SYSTEM LEAK TEST (LOCK UP PRESSURE)

REGULATOR TYPE	MEASURED START PRESSURE	MEASURED END PRESSURE	TIME HELD IN MINUTES	SYSTEM CHECK (OK)	REMARKS
Int Two-Stage					
1 st Stage	10	10	10	New OK	Ready to go
2 nd Stage					
2 nd Stage regulator pressure w/all appliances running:	_____ inches w.c.				

Piping Test for New Construction: 1st Stage 50 psig; 2nd Stage & Integral Two-Stage 10 psig. 10 minute minimum. Lock up pressure should not exceed 14 inches w.c.
Working Pressure Requirement: Working pressure should not fall below 10 inches w.c. or manufacturers recommendations.