

NC PERF 2024 - 2025 Safe Installation of Appliances Rebate Form

This form must be completed by a participating propane marketer. A safety inspection must be performed after the installation of each new qualifying appliance(s) and the acknowledgement of that inspection must be documented on this form in a manner acceptable to the NC PERF. Minimum requirements of the safety inspection are located on page 2 of this form.

This form and receipts showing purchase of each appliance must be submitted to the NC PERF for the customer to be eligible for consideration of any rebate(s). Failure to furnish all necessary documentation will result in the customer being declared ineligible for consideration of any rebate(s). The required inspections must be performed to conform to industry standard practices, NC Fuel Gas Code requirements, or local code requirements. The NC PERF and the Southeast Propane Alliance assume no liability for a customer being declared ineligible for consideration of any rebate(s).

Customer's Name Andy Oliver
 Mailing Address 5324 South NC 87
 City Graham State NC Zip 27253
 Phone: 336-264-0994 Email: N/A

Gas Company McLeod Oil
 Mailing Address 1103 Huffman Mill Rd.
 City Burlington State NC Zip 27215
 Email: mclead oil@hotmail.com Phone: 336-584-5662

Maximum of \$1500.00 per customer location per 32 month period

Description	Amount per unit	Number of units	Model number(s)	Serial number(s)	Total
Propane furnace or gas pack <input type="checkbox"/> New <input checked="" type="checkbox"/> Replacement	\$400.00	1	4YCC4030E1070A	24422459FA	400
Propane-fueled vented room heater or wall furnace <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$150.00				
Propane-fueled tankless water heater <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$300.00				
Propane-fueled storage-type water heater <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$300.00				
Dual fuel heat pump with propane as one fuel (includes hydronic) <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$400.00				
Propane-fueled cook top/range <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$50.00				
Propane-fueled clothes dryer <input type="checkbox"/> New <input type="checkbox"/> Replacement	\$50.00				
Maximum \$1500.00				Grand Total	400.00

CUSTOMER INSPECTION AND INSTALLATION RECORD

Dealer Name: McLeod LP Gas Inc
 Customer Name: Andy Oliver
 Address: 5324 South 1077
 City: Graham State: AL Zip Code: 37053
 Special Service Instructions: Test For Rebate

TANK IS OWNED BY: Customer Company
 Size of Container(s): 330 gallon AB Tank
 Container(s) located proper distances from buildings and property lines? Yes No
 Any sources of ignition within 10 feet? (i.e., air conditioners, grills, etc.) Yes No
 Is the container base substantial and noncombustible? Yes No
 Is the yard piping or tubing properly buried and/or protected? Yes No
 Is piping where entering the structure aboveground coated or wrapped with an inert material? Yes No
 Is piping where entering the structure underground installed and sealed in gas tight conduit? Yes No

APPLIANCES ON SYSTEM:

Furnace Crop Dryer Range/Oven Fireplace Log
 Gas Grill Clothing Dryer Space Heater Water Heater
 Lights Other: _____

SYSTEM LEAK OR PRESSURE TEST							
SINGLE STAGE	START PRESSURE		END PRESSURE	TIME HELD	LOCK-UP PRESSURE	SYSTEM OK	AGE
	(INCHES WC)		(INCHES WC)		IN WC		
TWO STAGE	1st	<u>10 PSI</u>	<u>10 PSI</u>	<u>10 min</u>	<u>10 PSI</u>	<u>Yes</u>	
	2nd	<u>12 in WC</u>	<u>12 in WC</u>	<u>"</u>	<u>12 in WC</u>	<u>Yes</u>	

Second Stage Regulator Secured? Yes No
 Second Stage Regulator located out of doors? Yes No
 — If not, is the vent outlet piped out of doors? Yes No
 Second stage regulator vent discharge downward or protected? Yes No
 Regulator vent discharge located:
 A minimum of 3 feet horizontally from:
 1. Any building opening below the level of discharge? Yes No
 A minimum of 5 feet in any direction from:
 1. Sources of ignition Yes No
 2. Intakes for direct vent appliances Yes No
 3. Mechanical air intakes Yes No
 Are all vented types of devices properly vented? Yes No
 Are there any unvented appliances? Yes (List: _____) No
 Has customer been made aware of the odorant added to propane, shown how to turn off tank valve, and been given written information? Yes No

Comments: _____
 Technician's Signature: [Signature] Date: 1-8-25
 Customer's Signature: Andy Oliver Date: 1-12-25

Required Signatures and Dates

Company Owner/Manager/ or Technician's signature:

I, Tim Oakley, certify that the required tests were performed in compliance with all applicable laws and regulations governing the installation.

Date of Inspection: 1-8-25

Check here if install is new home contractor construction (No receipt required)

Name of Builder/Contractor _____

(This paperwork must be submitted to SEPA within 30 days of appliance inspection date to receive rebate)

Disclaimer:

The propane marketer seeking a rebate must submit a full and complete Application form. Submission of the Application form constitutes a representation on the part of the participating propane marketer that the required safety test was completed. A safety inspection must be performed by the participating propane marketer after the installation of each new qualifying appliance(s). The safety inspection for qualifying appliance installations consists of the following: 1) a leak test; 2) a pressure test if required by applicable laws, rules and regulations; and 3) a flow and lock up test on the regulator[s]. The propane marketer agrees to comply with all laws, rules and regulations governing the installation of the qualifying appliance and with the manufacturer's installation instructions. The Southeast Propane Alliance and NC PERF assumes no responsibility whatsoever for the installation, inspection, or testing of the qualifying appliance(s) or any associated gas system and, by issuing a rebate, makes no representation, warranty or guarantee regarding the qualifying appliance(s) or the associated gas system. The Southeast Propane Alliance and NC PERF disclaims any liability for any personal injury, property damage, business losses or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly arising from the installation of the qualifying appliance(s).

Please submit your 2-page rebate form and receipt(s) to:

Mail: NC PERF
5109 Hollyridge Dr.
Suite 101
Raleigh, NC 27612

Fax: 919-781-7481

Email: info@ncpropanerebates.com

As of 07/01/24

L & M Nicholson Heating and Air, Inc.
1404 W. Greensboro Chapel Hill Rd.
Snow Camp, NC 27349



L&MNICHOLSON
HEATING & AIR, INC

Invoice 47002634
Invoice Date 11/20/2024
Completed Date 11/20/2024
Customer PO
Payment Term Due Upon Receipt
Due Date 11/20/2024

Billing Address
Andy Oliver
5324 South North Carolina 87
Graham, NC 27253 USA

Job Address
Andy Oliver
5324 South North Carolina 87
Graham, NC 27253 USA

Description of Work

Task #	Description	Quantity	Your Price	Your Total
Unit Replacement	Removed existing system and Installed new 14.3 SEER2 Trane Gas Package System. This price includes Permits, Inspections, Equipment, Materials, and Labor. Warranty: 20 Years on Heat Exchanger 10 Years on Compressor, Coils, and Parts 1 Year on Labor	1.00	\$7,185.00	\$7,185.00
Repairs	Installed all new supply and return ducting to boots in floor. This price includes Materials and Labor.	1.00	\$2,000.00	\$2,000.00

Potential Savings \$0.00
Sub-Total \$9,185.00
Tax \$0.00
Total Due \$9,185.00
Balance Due \$9,185.00

Thank you for your business. Questions call 336-376-9998 or TOLL -FREE 877-376-9998.

This invoice is agreed and acknowledged. Payment is due upon receipt. A service fee will be charged for any returned checks, and a financing charge of 1% per month shall be applied for overdue amounts.

I find and agree that all work performed by L & M Nicholson Heating and Air, Inc. has been completed in a satisfactory and workmanlike manner. I have been given the opportunity to address concerns and/or discrepancies in the work provided, and I either have no such concerns or have found no discrepancies or they have been addressed to my satisfaction. My signature here signifies my full and final acceptance of all work performed by the contractor.