

**McLAMB'S LP GAS & SUPPLY**  
3469 NC 242 SOUTH BENSON, NC 27504  
(919) 894-3842 info@mcclambslpgas.com

**PROPANE SAFETY  
SHEET**

Service Date 4/18/2025 County Johnston  
Account Number 12180-02 Directions Same as loc 1  
Name Tim Lee  
Address 6552-C Godwin Lake Rd Rental House  
Dunn NC 28334  
Phone 919-894-71431 Closest Customer \_\_\_\_\_

APPLIANCE	WORK DESCRIPTION
TYPE <u>Tankless Water</u>	
MANUFACTURER <u>Rinnai</u>	
MODEL # <u>RE160</u>	
SERIAL # <u>STW9-111608</u>	
LOCATION <u>Duffside</u>	
BTU <u>MAX 160,000</u>	
AGE <u>New</u>	
MANUAL SHUTOFF <u>✓</u>	
VENTING <u>✓</u>	
SEDIMENT TRAP <u>✓</u>	
RED TAG <u>✓</u>	

TANK OWNED BY: Company \_\_\_\_\_ Customer X

The customer acknowledges that he/she (1) knows how to turn off gas in emergencies, (2) has smelled and can detect propane odor, (3) has received other safety instructions, (4) understands any gas problems and corrections, (5) is satisfied with the work performed, and (6) that the customer acknowledges tank ownership as indicated above. The serviceman acknowledges that he/she (1) performed odor test, (2) performed a leak test and pressure test, and (3) has given the customer safety instructions.

Customer Signature As of home at Serviceman Signature [Signature]

TANK SPECIFICS					
SIZE	SERIAL #	MFG	MFG DATE	LOCATION	CONDITION
<u>120</u>	<u>I-4339634</u>	<u>2024</u>	<u>2025</u>	<u>Duffside</u>	<u>New</u>
PIPING/REGULATOR					
REGULATOR TYPE	PIPING MATERIAL	PIPING SIZE	REG LT DATE	MFG/MODEL	REG VENT PROTECT
Int Two-Stage	<u>BS</u>	<u>3/4</u>	<u>24</u>	<u>Fisher</u>	<u>depress</u>
1 <sup>st</sup> Stage					
2 <sup>nd</sup> Stage					

SYSTEM LEAK TEST (LOCK UP PRESSURE)					
REGULATOR TYPE	MEASURED START PRESSURE	MEASURED END PRESSURE	TIME HELD IN MINUTES	SYSTEM CHECK (OK)	REMARKS
Int Two-Stage	<u>10</u>	<u>10</u>	<u>12</u>	<u>OK</u>	<u>New</u>
1 <sup>st</sup> Stage					
2 <sup>nd</sup> Stage					
2 <sup>nd</sup> Stage regulator pressure w/all appliances running: <u>9.42-9.54</u> inches w.c.					

**Piping Test for New Construction:** 1<sup>st</sup> Stage 50 psig; 2<sup>nd</sup> Stage & Integral Two-Stage 10 psig. 10 minute minimum. Lock up pressure should not exceed 14 inches w.c.  
**Working Pressure Requirement:** Working pressure should not fall below 10 inches w.c. or manufacturers recommendations.

Timmy Lee.

McLamb's LP Gas & Supply

Customer Transaction Details

25-Mar-25 12:07 By: 9

Page: 1

T	D	N								E	I	
A	E	E	Joyce Godwin		Inv:258261	Term:17	Sales Person:7	31-Jan-25 11:00			L	S
X	F	T	Scan Number	Description	Part #	Qty	Price One	Sell Price	Per Qty	Ext	L	C
X			RE160EP	RINNAI LP GAS RE160EP	RE160EP	1	1099.00	1099.00 /	1	1099.00		
X			WHITEGOODS TAX	WhiteGoods Tax for item RE16	WHITEGOODS TAX	1	3.00	0.00 /	0	3.00		
X			PCD09-SHS	RINNAI COVER WH	PCD09-SHS	1	149.00	149.00 /	1	149.00		
X			098268483482	TANKLESS VALVE KIT	098268483482	1	89.00	89.00 /	1	89.00		
Number: 1797 Name: Joyce Godwin						CHECK	1,430.45	Sub Total		1340.00		
								Total Tax		90.45		
								Grand Total		1430.45		



**McLAMB'S L.P. GAS & SUPPLY CO., Inc.**

**3469 NC 242 South • Benson, NC 27504**

**Phone: 919-894-3842 • Fax: 919-894-8025**

email: [mclambslpgas.com](mailto:mclambslpgas.com)

Hardware • Metal Roofing & Siding • Dog Kennels • Rescreening & Glass Cutting  
Mobile Home, Electrical, Plumbing & Farm Supplies



CUSTOMER'S ORDER NO. 12180-02		PHONE		DATE 4/18/25	
NAME Tim Lee					
ADDRESS					
MAKE		MILEAGE		LIC. #	
PAID BY D		CASH	C.O.D.	CHARGE X	ON ACCT.
PAID OUT		MOSE. RET'D.			
QUAN.	DESCRIPTION			PRICE	AMOUNT
	Regulator				85.00
	Tubing / fittings				173.49
	Labor				95.00
					353.49
	Water heater at Rental Hse				23.86
				TAX	
				TOTAL	\$ 377.35
All claims and returned goods MUST be accompanied by this bill.					
RECEIVED BY:					
0055609					