



2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Customer #:	3752869
Payment Terms:	Payment due in 30 days
Invoice #:	32588727
Invoice Date	2025-09-26
Total Due	\$2,385.53

Amount Enclosed: \$ _____

MIKE & KIM HARRIS
PO BOX 936
SPRUCE PINE, NC 28777

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

000375286900002385534

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
MIKE & KIM HARRIS		332 WALTER THOMAS RD - SPRUCE PINE, NC 28714		3752869	32588727	2025-09-26
Quantity	Item Number	Description	Unit Price	TOTAL		
1.00	071870	Safety Check/inspection	\$112.5000	\$112.50		
1.00	Discount - Labor	Labor Discount	-\$117.9000	-\$117.90		
1.00	Discount - Labor	Labor Discount	-\$117.9000	-\$117.90		
1.00	TR3003WN	TOPLOAD WASHER HYBRID CONTROL WHITE	\$1,179.0000	\$1,179.00		
1.00	DR3003WG	REAR CONTROL GAS DRYER WHITE	\$1,179.0000	\$1,179.00		

Tank/Equipment: Laundry Products -

For Fuel or Service At:

332 WALTER THOMAS RD - SPRUCE PINE, NC 28714

Sub Total	\$2,234.70
Consumables	
Tax Total	\$150.83
TOTAL DUE	\$2,385.53

BLOSSMAN GAS & APPLIANCE
2138 WEST US HIGHWAY 19E
BURNSVILLE, NC 28714

Safety Check



Date: 09-26-2025 Work Order #: 32588727

Acct #: 3752869 Branch: BURNSVILLE

Name: MIKE & KIM HARRIS

Address: 332 WALTER THOMAS RD

City: SPRUCE PINE State: NC Zip Code: 28714

Phone #: (828) 467-6707 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a New Install

Appliances

Appliance: Water Heater	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Range/Cooktop	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Dryer	Type: Gas	Manufacturer: Speed queen
Age: New	Input BTU: 22,500	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Gas Logs	Type: None	Manufacturer:
Age:	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Container(s)

Type: Tank	Desc: 500AG AM2SE058325	Owned By: Company
Size: LP500AG	Serial #: AM2SE058325	Mfg.: Other
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: 4403
Flow Pressure: 10	Lock-up Pressure: 10.5	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Kosan	Model: 998-03
Flow Pressure: 11	Lock-up Pressure: 12	

System Leak Check

Start Pressure: 9 w.c	End Pressure: 9 w.c	Time Head: 3 MINUTES
-----------------------	---------------------	----------------------

Piping Pressure Test

Start Pressure: Na psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, MIKE & KIM HARRIS

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:
Safety Check
Fuel Type: Propane
Work Order #: 32588727
New appliance: Dryer

Service Technician: EDDIE MCCOURRY
