

Safety Check



Date: 12-30-2025 Work Order #: 5638917

Acct #: 5638917 Branch: MARSHVILLE

Name: Chett Baker

Address: 5726 Old Pageland Marshville Rd

City: Monroe State: NC Zip Code: 28112

Phone #: (704) 465-5809 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a Existing Installation

Appliances

Appliance: Furnace	Type: Gas	Manufacturer: American standard
Age: New	Input BTU: 90,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Cooking Products	Type: Gas	Manufacturer: Fridgear
Age: New	Input BTU: 20,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Water Heater	Type: Gas	Manufacturer: Rheem
Age: New	Input BTU: 36,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Gas logs	Type: Gas	Manufacturer: Empire
Age: New	Input BTU: 26,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Container(s)

Type: Tank	Desc: 250@ residence	Owned By: Company
Size: LP250AG	Serial #: 1120082_Marshville	Mfg.: Quality Steel
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: Y39
Flow Pressure: 9.8	Lock-up Pressure: 10.2	

2 PSI	Manu.: Rego	Model: Y39
Flow Pressure: 1.8	Lock-up Pressure: 2.1	

2nd/Final Stage	Manu.: Maxitrol	Model: 325
Flow Pressure: 10.4	Lock-up Pressure: 11.1	

System Leak Check

Start Pressure: 110 psi	End Pressure: 110 psi	Time Head: 10 MINUTES
-------------------------	-----------------------	-----------------------

Piping Pressure Test

Start Pressure: NA psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------

CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAIMER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Chett Baker

Know how to turn off gas in case of emergency,
Have smelled propane/natural gas and can detect its odor,
Have received the consumer safety information,
I am satisfied with the service work performed.

Customer Signature



Comments:
Safety Check
Fuel Type: Propane

Work Order #: 0

Service Technician: DANNY MORGAN
