

Safety Check



Date: 12-12-2025 Work Order #: 5547197

Acct #: 5547197 Branch: MARSHVILLE

Name: Ubaldo Varela Cataneo

Address: 1701 Lake Monroe Drive

City: Monroe State: NC Zip Code: 28112

Phone #: (810) 922-9012 Alt Phone #: _____

Services Performed: Walk-through Visual Inspection, Leak Check, Safety Check on a Existing Installation

Appliances

Appliance: Water Heater	Type: Gas	Manufacturer: Rinnai
Age: New	Input BTU: 199,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Range/Cooktop	Type: Gas	Manufacturer: Kitchenaid
Age: 4	Input BTU: 20,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Dryer	Type: Electric	Manufacturer: Lg
Age: 2	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Appliance: Gas Logs	Type: Gas	Manufacturer: Empire
Age: 10Plus	Input BTU: 30,000	Appliance Converted: LP
Control Safety System: OK	Combustion Chamber: OK	Combustion Air: OK
Venting System: OK	Red Tagged: No	

Appliance: Furnace	Type: Electric	Manufacturer: Duchane
Age: 5	Input BTU:	Appliance Converted:
Control Safety System:	Combustion Chamber:	Combustion Air:
Venting System:	Red Tagged:	

Container(s)

Type: Tank	Desc: customer owned 120	Owned By: Company
Size: LP120AG	@ Residence Serial #: M2303019	Mfg.: Arcosa
Condition: OK	Relief Value Cap: OK	Fitting Leak Test: OK

Regulator Operations

1st Stage	Manu.: Rego	Model: TR9
Flow Pressure: 9.8	Lock-up Pressure: 10.4	

2 PSI	Manu.: NA	Model:
Flow Pressure:	Lock-up Pressure:	

2nd/Final Stage	Manu.: Rego	Model: B4
Flow Pressure: 10.4	Lock-up Pressure: 11.5	

System Leak Check

Start Pressure: 90 psi	End Pressure: 90 psi	Time Head: 10 MINUTES
------------------------	----------------------	-----------------------

Piping Pressure Test

Start Pressure: NA psi	End Pressure: N/A psi	Time Head: N/A N/A
------------------------	-----------------------	--------------------


CO READINGS 0 ppm (Based on the U.S. Consumer Product Safety commission, readings should be below 30ppm.)

DISCLAMIER: This Safety Check/Leak Check covers Propane/Natural gas items and equipment visible and accessible to the service representative and represents the conditions existing on this date. It does not cover latent or manufacturing defects, the internal working of equipment, structural components, or high temperature plastic vent (HTPV), and cannot be construed to cover future or unforeseen deficiencies.

I, Ubaldo Varela Cataneo

Know how to turn off gas in case of emergency,
 Have smelled propane/natural gas and can detect its odor,
 Have received the consumer safety information,
 I am satisfied with the service work performed.

Customer Signature

A handwritten signature in black ink, reading "Lann Varela", enclosed within a thin black rectangular border.

Comments:

Safety Check

Fuel Type: Propane

Work Order #: 5547197

New appliance: Water Heater

Service Technician: DANNY MORGAN
