



P.O. BOX 5066
ASHEVILLE, NC 28813

Customer #:	2505079
Payment Terms:	COD
Invoice #:	35346827
Invoice Date	2026-04-03
Total Due	\$0.00

Amount Enclosed: \$ _____

CHARLOTTE KASSAB
STEVEN TURNER
356 ROSE HILL ROAD
ASHEVILLE, NC 28803

BLOSSMAN GAS & APPLIANCE
P.O. BOX 5066
ASHEVILLE, NC 28813

0002505079000000000000

Customer Name		Delivery/Service Address	Cust #	Invoice #	Inv Date
CHARLOTTE KASSAB		356 ROSE HILL ROAD - ASHEVILLE, NC 28803	2505079	35346827	2026-04-03
Quantity	Item Number	Description	Unit Price	TOTAL	
1.00	071870	Safety Check/inspection	\$131.2500	\$131.25	
1.00	LABOR	INSTALL TANKLESS	\$350.0000	\$350.00	
1.00	RE180IP	Rinnai RE Series 8.5 GPM Indoor NCTWH - LP s # WC. UA-021887	\$1,199.9900	\$1,199.99	
1.00	071636	REPLACED 2ND STAGE BACKMOUNT REGULATOR	\$186.8600	\$186.86	
1.00	071625	REPLACED 1ST STAGE COMPACT REGULATOR	\$148.7500	\$148.75	

Tank/Equipment: Water Heater - CHARLOTTE KASSAB/356 ROSE HILL ROAD//ASHEVILLE NC 28803 RINNAI

For Fuel or Service At:

356 ROSE HILL ROAD - ASHEVILLE, NC 28803

Sub Total	\$2,016.85
Consumables	\$9.99
Tax Total	\$141.88
Your credit card will be charged on 04/04/2026.	
TOTAL DUE	\$0.00

PRIORITY BILLING

04/03/2026 - Technician: 053 CODY CURTIS - Work Performed: Appliance Sale - RE180IP Rinnai RE Series 8.5 GPM Indoor NCTWH - LP 1 WC.UA-021887

04/03/2026 - Technician: 053 CODY CURTIS - Work Performed: Safety Check System - Replaced outdated crimp 1st and 2nd stage regulators. Removed old water heater. Installed new rinnai. Old vent falling apart and replaced. Trac pipe removed and ran with blk iron. Both repaired no charge, quoted install. Safety check add to existing.

BLOSSMAN GAS & APPLIANCE
P.O. BOX 5066
ASHEVILLE, NC 28813

www.blossmangas.com |828.667.0437